

ultra**D** Water MeterManual



Dynaflox Shanghai Co., Ltd. 03/2016



Contents

| 1. | Overview and Warnings | 1 |
|----|---------------------------------------|------|
| | Technical Specifications | |
| | Installation | |
| | 3.1 Dimensions and Installation | |
| | 3.2 Location and Position | |
| | Display Description | |
| | 4.1 Digital Display (DN15-25) | |
| | 4.2 Digital Display (DN32-300) | |
| | Modbus Communication Protocol | |
| | 5.1 Modbus-RTU Protocol Introduction | 7 |
| | 5.2 Modbus-RTU Protocol Message Frame | 7 |
| | 5.3 Register List | |
| 6. | Handheld Operator Description | . 11 |
| | Replace Battery | |
| | Troubleshooting and sales commitments | |
| | 8.1 Common Troubleshooting | 13 |
| | 8.2 Warranty | |
| | | |



1. Overview and Warnings

The measurement method of ultraD water meter is based on dual path, transit-time, ultrasonic technology. The ultraD water meters combine measurement, calculation and display, and can be widely used for regional water supply systems and cooling water systems, etc. Read these instructions carefully before beginning installation and save them for future reference.

- > This product is a precise measuring instrument and has been thoroughly inspected and tested before shipment. So the calibration, maintenance and replacement should be operated by professionals. For more technical support, please contact us.
- > The lead seal of the meter should not be destroyed. Otherwise, we are not responsibility for warranty.
- > This product is suitable for measuring clean water or homogeneous liquid in full filled pipes, not suitable for measuring underground muddy water.
- > To select the installation location, please pay attention to the following points:
- 1. Do not install the meter near the variable frequency pump, electric machinery or other electromagnetic interference environment.
- 2. If the installing pipe is connected by contracted pipe, expanded pipe, bends or other flow disturbers, please select other installation location or rectify the pipeline (If you need the meter without installation requirement of straight pipe, please contact the factory).
- 3. The preferred installation location is horizontal pipe, followed by the vertical pipe with upward (or obliquely upward) flow, avoiding the downward (or obliquely downward) flow to prevent the partially filled pipe.
- 4. Since air collects at the highest point of the pipe, installation of the water meter should be at the lowest point to avoid measuring errors.
- Before installing the meter, ensure that the circulation line has been cleaned to prevent any stones, sand or other debris.
- It is recommended to install valve in the pipeline before and after the meter for easy maintenance. After the meter is installed and before opening the pipeline valves, be careful not to form a negative pressure in the pipe of the meter installation location, in order to avoid damage to the meter.
- After installation is complete, it is recommended to keep the lid closed to avoid direct sunlight exposure.
- If you do not use cable communications, please keep the cable for later use.
- When communicating, do not make any cables of this product near heat sources to avoid damage to the cable insulation layer caused by the deformation of the cable, so as not to cause fire or electrical accident.



2. Technical Specifications

| Maximum Working Pressure | 1.6MPa |
|-------------------------------------|--|
| Temperature Class | T30, T50 (Higher temperature customizable) |
| Accuracy Class | Class 2 (ISO4064:2005) |
| Battery Life | 10 years, 20 years |
| Ingress Protection | IP68 |
| Environment Temperature | -20~70°C, ≤100%RH |
| Pressure Loss | △p10 |
| Climatic and Mechanical Environment | Class C |
| Electromagnetic Environment Class | E2 |
| Flow Profile Sensitivity | U3/D0 |
| Display | 9 digit LCD Display + prompts Cumulative flow (m³), Instantaneous flow (m³/h), Flow direction, Alarm, Battery level, Output mode, etc. |
| Connections | Threads (DN15-40), Flanges (DN50-300) according to DIN (EN1092-1) (Other standards customizable) |
| Date Storage | Store the data in last 7×24h, 365 days and 72 months |
| Output (optional) | RS485 (ModBus), M-Bus, OCT pulse, two wire 4-20mA |
| Accessories | Wireless GPRS/GSM, Wireless handheld operator |
| Power Consumption | <0.5mW |
| Cable Length | Standard 1m (Other requirements customizable) |




3. Installation


3.1 Dimensions and Installation

| Meter | (mm) | 15 | 20 | 25 | 32 | 40 |
|----------------|------------------|------|------|------|-------|-------|
| Size | (inch) | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 |
| L- Lengtl | L- Length (mm) | | 195 | 225 | 260 | 300 |
| B - Width | B - Width (mm) | | 100 | 100 | 90 | 130 |
| H - Heigh | H - Height (mm) | | 83 | 83 | 130 | 132 |
| H1 - Heig | H1 - Height (mm) | | 166 | 166 | 226 | 225 |
| h - Heigh | h - Height (mm) | | 22 | 22 | 19 | 20 |
| L1-Length (mm) | | 260 | 290 | 345 | 385 | 430 |
| Weight | SS | 1.0 | 1.2 | 1.4 | 4.8 | 6.5 |
| (kg) | Brass | 0.14 | 0.52 | 0.81 | 1.57 | 3.39 |

DN15-DN25





DN32-DN40





DN50-DN300





| Meter | (mm) | 50 | 65 | 80 | 100 | 125 | 150 | 200 | 250 | 300 |
|-----------------|-----------|------|-------|------|------|------|-------|------|-------|-------|
| Size | (inch) | 2 | 2 1/2 | 3 | 4 | 5 | 6 | 8 | 10 | 12 |
| L- Length (mm) | | 200 | 200 | 225 | 250 | 250 | 300 | 350 | 450 | 500 |
| B - Width | (mm) | 125 | 142 | 186 | 204 | 240 | 285 | 340 | 395 | 445 |
| H - Height (mm) | | 180 | 185 | 213 | 226 | 231 | 280 | 327 | 374.5 | 414.5 |
| h - Height (mm) | | 65 | 68 | 93 | 102 | 112 | 142.5 | 170 | 197.5 | 222.5 |
| d x n | | 18x4 | 18x4 | 18x4 | 18x4 | 18x4 | 22x8 | 22x8 | 22x12 | 22x12 |
| K (mm) | | 125 | 145 | 160 | 180 | 210 | 240 | 295 | 355 | 410 |
| Pressure (MPa) | | 1.6 | 1.6 | 1.6 | 1.6 | 1.6 | 1.6 | 1 | 1 | 1 |
| Weight | SS | 9 | 11 | 13 | 16 | 21 | 29 | 46 | 60 | 74 |
| (kg) | Cast Iron | 6 | 6.5 | 13 | 16 | 21 | 30 | 45 | 55 | 68 |

Remarks


d: diameter of bolt holes, n: numbers of bolt holes, K: central circle diameter of bolt holes

 $^{{\}rm *Other\ requirements\ customizable}$




3.2 Location and Position

Only suitable for bulk water meters from DN50 to DN300




C) Recommendations for achieving top performance



3 pipe diameters before and after elbows (90°)

Minimum of 6 pipe diameters before and after

Minimum of 10 pipe diameters after pumps



Minimum of 6 pipe diameters before T connections

Minimum of 6 pipe diameters after strainers

Flow Directi

3 pipe diameters before and after elbows (90°) in vertical installations




4. Display Description

The cumulative flow, instantaneous flow and the status flag are displayed on the LCD screen. It can offset the drawbacks of the past magnet rod operation which requires to switch the display screen to see all parameters of the meter. Operators can check the meter status at any time without a magnet rod.

Digital display contents are as follows:


4.1 Digital Display (DN15-25)



LCD display: The switch between different screens is achieved by the light button. The light button can work normally when the light intensity meet the requirement. When it's dark, a lamp can be used to illuminate the light button.



4.2 Digital Display (DN32-300)





- Flow direction
- Alarm, means empty pipe or error
- The pulse output function has been open
- Infrared communication
- The battery power is low, please replace the battery as soon as possible
- Leakage occurred in the pipe
- m³ Volume units (can be set GAL (US gallons) and L units according to customer requirements)
- m³/h Flowrate units (can be set GPM (US gallons) and L/min units according to customer requirements)

5. Modbus Communication Protocol

5.1 Modbus-RTU Protocol Introduction

Ultrasonic water meter supports Modbus-RTU protocol. Baud rate: 1200, 2400, 4800, 9600 optional. Character type 8 data bits, no parity bit, 1 stop bit

5.2 Modbus-RTU Protocol Message Frame

| Start Bit | Address Code | Function Code | Data <i>i</i> | Area | CRC Code | Terminator |
|--------------------|-----------------|------------------|----------------------------------|------------------------------------|------------|--------------------|
| 4 characters' time | 1 byte | 1 byte | 2 bytes (register address) | 2 bytes (number of register) | 16 digital | 4 characters' time |

- ♦ Start Bit: under RTU mode, messages start to send by interval time of 4 characters.
- ◆ Address Code: Within a network, the address code is unique, range: 1--247. Address 0 is used as a broadcast address, not for stand-alone communications.
 - Function Code: the water meter only uses function code 03, namely: read register data.
- ◆ Data Area: corresponds to the function code 03, there are a total of four bytes when the mainframe sends commands:



| 2 bytes | 2 bytes |
|--------------------|----------------------|
| (register address) | (number of register) |

The first two bytes are the first address of the register to be read;

The last two bytes are the number of register to be read (up to 22).

| 1 byte the number of bytes in data | N bytes |
|------------------------------------|------------------------|
| area | specific register data |

When the machine responds, the first byte is the number of bytes in data area (not including itself);

The following bytes in data area are the value of the register to be read; the length is determined by the first byte.

- ◆ CRC Code: two-byte error detection code. Low byte is in front of high byte.
- ◆ Terminator: after the transfer of the last character, the pause time of 4 character marks the end of the message.

5.3 Register List

| Baud rate | 1200 | 2400 | 4800 | 9600 | |
|----------------|--------|-----------|---|------|--------|
| Parity bit | None | | | | |
| Stop bit | 1 | | | | |
| Data bit | 8 | | | | |
| | | | | | |
| Address | Length | Data Type | Data Content | Unit | Remark |
| 0 | 2 | long | Instantaneous flowrate | L/h | |
| 2 | 2 | long | Positive cumulative flow (integer part) | m3 | |
| 4 | 2 | long | Positive cumulative flow (decimal part) | mL | |
| 6 | 2 | long | Negative cumulative flow (integer part) | m3 | |
| 8 | 2 | long | Negative cumulative flow (decimal part) | mL | |
| 10 | 2 | long | Run time | s | |
| 12 | 2 | long | Fault time | s | |
| 14 | 2 | long | Battery voltage | mV | |
| 16 | 1 | int | Error code | | |
| | | | | | |
| Historical dat | a | | | | |
| 0x9000 | 1 | int | Number of historical data per hour | | |
| 0x9001 | 1 | int | Number of historical data per day | | |



| | | | uit | rad Series water weter war |
|-----------------|---|-------|---|----------------------------|
| 0x9002 | 1 | int | Number of historical data | |
| | | | per mouth | |
| Historical data | 1 | T | T | |
| 0xA000 | 2 | long | Time | |
| 0xA002 | 2 | long | Positive cumulative flow | m3 |
| | | | (integer part) | |
| 0xA004 | 2 | long | Positive cumulative flow | mL |
| | | | (decimal part) | |
| 0xA006 | 2 | long | Negative cumulative flow (integer part) | m3 |
| | | | Negative cumulative flow | |
| 0xA008 | 2 | long | (decimal part) | mL |
| 0xA00A | 2 | long | Time | |
| | | 10118 | Positive cumulative flow | |
| 0xA00C | 2 | long | (integer part) | m3 |
| | | 1. | Positive cumulative flow | |
| 0xA00E | 2 | long | (decimal part) | mL |
| 0.4040 | 2 | 1 | Negative cumulative flow | 2 |
| 0xA010 | 2 | long | (integer part) | m3 |
| 0xA012 | 2 | long | Negative cumulative flow | mL |
| UXAU12 | | long | (decimal part) | IIIL |
| | | | | |
| Historical data | 1 | | 1 | |
| 0xB000 | 2 | long | Time | |
| 0xB002 | 2 | long | Positive cumulative flow | m3 |
| | | | (integer part) | |
| 0xB004 | 2 | long | Positive cumulative flow | mL |
| | | | (decimal part) | |
| 0xB006 | 2 | long | Negative cumulative flow (integer part) | m3 |
| | | | Negative cumulative flow | |
| 0xB008 | 2 | long | (decimal part) | mL |
| 0xB00A | 2 | long | Time | |
| | | | Positive cumulative flow | |
| 0xB00C | 2 | long | (integer part) | m3 |
| 0.005- | | 1. | Positive cumulative flow | |
| 0xB00E | 2 | long | (decimal part) | mL |
| 0vR010 | 2 | long | Negative cumulative flow | m ² |
| 0xB010 | 2 | long | (integer part) | m3 |
| 0xB012 | 2 | long | Negative cumulative flow | mL |
| 0,0012 | | 10116 | (decimal part) | 1115 |
| | | | | |
| Historical data | 1 | 1 | 1 | 1 |
| 0xC000 | 2 | long | Time | |



ultraD Series Water Meter Manual

| 0xC002 | 2 | long | Positive cumulative flow (integer part) | m3 | |
|---------------|------------|--------------------------------------|--|----|--|
| 0xC004 | 2 | long | Positive cumulative flow (decimal part) | mL | |
| 0xC006 | 2 | long | Negative cumulative flow (integer part) | m3 | |
| 0xC008 | 2 | long | Negative cumulative flow (decimal part) | mL | |
| 0xC00A | 2 | long | Time | | |
| 0xC00C | 2 | long | Positive cumulative flow (integer part) | m3 | |
| 0xC00E | 2 | long | Positive cumulative flow (decimal part) | mL | |
| 0xC010 | 2 | long | Negative cumulative flow (integer part) | m3 | |
| 0xC012 | 2 | long | Negative cumulative flow (decimal part) | mL | |
| | | | | | |
| Definition of | error code | | | | |
| | 10 | Sound wave receiving timeout | Check whether blank pipe or bubbles in water | | |
| | 01 | Velocity out of range | | | |
| | 02 | Water temperature out of range | | | |



6. Handheld Operator Description

The accumulative flow, instantaneous flow and the status flag of the meter are displayed on the LCD screen without additional operations, but in order to meet some users' special requirements, the company has developed a special tool to configure the meter - wireless handheld operator. It has the following functions:

- 1. Read the current data, including accumulative flow, instantaneous flow, battery level, time and host number.
- 2. Query the historical data: the number of records, historical accumulative flow, etc. The data is saved in the handheld operator as .CSV format, and can be open by excel when exported to a computer.
- 3. Parameter settings: including user setting, factory setting, pulse setting and the current setting. The factory setting can be statically set to zero, cut the zero point, set the time and change the password, meter factors and accumulative flow, etc.
- 4. Parameter query: including software version, MBUS, pulse, display units and current, etc. The relevant operating instructions of infrared handheld operator refer to "infrared handheld operator manual." For customers who need to order infrared handheld operator, please specially note when ordering the meters.

Note the following information when using infrared handheld operator:

- 1. The infrared handheld operator must be used within 0.5m from the infrared probe, beyond the scope will lead to failure reading.
- 2. Please align the infrared probe at the infrared interface of the meter. Failure reading indicates that the infrared probes are not aligned, please re-align.
- 3. The infrared handheld operator is powered by three 5-size rechargeable battery. When the battery is fully charged, the voltage is usually 4.2V-5.3V. When the battery voltage is lower than 3.3V, it indicates that the voltage is too low, please recharge the battery timely, otherwise it will shut down automatically or fail to boot.
- 4. The factory setting can be only set by the factory in principle, and has been password protected. In some special circumstances, if customers need to use the factory settings, please contact the factory to get a password.



About the detail operation, please see our handheld operator manual.

7. Replace Battery

This product uses 3.6V lithium battery and the battery can be used for more than 10 years.

When battery voltage is low, the screen will display the symbol, indicating that the user needs to replace the battery.



8. Troubleshooting and sales commitments

8.1 Common Troubleshooting

If the product has the following problems, please refer to the solution. If other faults, please contact the factory for repair.

| Fault code | | Fault Detail | Solutions | |
|--------------|--------------------|---|--|--|
| Err 01 | | Operation error | Contact factory | |
| F== 40 | Long-term display | Empty pipe Meter failure | 1.Make the pipe be filled with water 2.Contact factory | |
| Err 10 | Frequently display | The liquid has excessive bubbles or impurities | Release the air or remove the impurities. | |
| Display" 🗖 " | | Battery voltage is low. | Replace the battery. | |

8.2 Warranty

Dynaflox follows the enterprise culture of "Respect, Harmony, Innovation and Integrity", respect the interests of our customers, we solemnly promise to you:

- 1. From the date of delivery, meters enjoy one year free warranty.
- 2. If user demands, the company will appoint professional technician to help users solve the problem at the first time.
- 3. Dynaflox will not be responsible for and will have no obligation under the Warranty to the following situations:
- 1) Damage caused by human factors, such as smashing, wrestling, etc.
- 2) Damage caused by irresistible factors, such as lightning, etc;
- 3) The product is opened, modified or repaired by any person other than a technician from Dynaflox or if it is repaired using unauthorized parts.
- 4) Damages caused by failing to follow the instructions of the manual to install, use or maintain the meter.
- 5) For the above reasons the maintenance expenses should be beared by users.



| Nivo | Tech |
|------|-------------|
| www | nivotech dk |

Dynaflox Shanghai Co., Ltd.

www.dynaflox.com

*The Company reserves the right to modify the information of the products. It is subject to change without notice

*Publication Date: June, 2015